



Woodstock, Vermont *The Shire Town of Windsor County*

TOWN - VILLAGE MANAGER GOVERNMENT

Town Hall • P.O. Box 488 • Woodstock, Vermont 05091 • 802/457-3456

**Invitation to Bid
Prosper Road
Paving, gravel, and ditch work
2019**

Addendum # 1

Paving:

- There should be key cuts ground out to Route 4 and blending into Rose Hill. Also there should be key cuts on the other side at the intersection of Route 12.
- Paving should have a 1" base and 2" finish layer. This was previously specified as 1" shim and 2" overlay.

Gravel Surface:

- Culverts are to be replaced where specified/marked with 24" epoxy lined corrugated steel culverts or equivalent.
- Gravel should be ¾" Hardpak that is good quality.

Ditch Work:

- Use erosion netting for areas with less than 5% grade.
- Bring ditch depth up as necessary but, use judgement to allow flow through culverts.
- Stop ditching at the culvert after the Mt. Tom parking lot.
- Measurements on the map are approximate.
- Follow VTrans guidelines for the Stormwater Laws.
- Stone should be 6" below road grade.
- Leave the trees and stone walls alone. Conservation of trees and stone walls are important.
- Use best judgement and specify lengths and amounts on bids.
- The 3" of Hardpak is not to be mix in with the current road bed, but to be scarified so that the road bed and new Hardpack bind.

Thank you for your interest.

